



**City of Hickory
Engineering Department**

76 N Center St NE
Hickory, NC 28601
Phone: (828) 323-7431
Fax: (828) 323-7476
kwinkler@hickorync.gov

ADDENDUM NO. 2

City of Hickory Public Safety Upgrades
City of Hickory Bid Number 21-012
April 6, 2021

The information listed below revises, supersedes and clarifies the bid documents issued for this project. These items should be incorporated in their entirety into your final bids. Any questions regarding this addendum should be directed to Kelly Winkler, P.E., Senior Civil Engineer, City of Hickory at (828) 323-7431.

1. **General:** The bid opening date is revised and will end on April 20, 2021 at 1:30 p.m. at the Engineering Department in City Hall. The opening will be informal. City Hall is located at 76 N. Center Street in Hickory.
2. **General:** Since the site is secured by a gate and does not have a schedule as to being open or closed, a non-mandatory pre-bid meeting will be held on site on April 13, 2021 at 10:00 am. The address for the project is: 1107 21st Street Drive SE, Hickory NC 28602.
3. **Clarification:** The proposed restroom/shower facility is not part of this contract. The utilities for this structure (water, sewer, electrical) will be terminated near the locations shown on the plans. These utilities will be identified for future connection to the structure.
4. **Clarification:** A single 4" PVC conduit will be added from near the electrical termination, noted in item 3, under the asphalt to the training simulator pad. A single 4" PVC conduit will be added from the training simulator pad, under the asphalt, to the training building pad. All ends of the conduit will be marked for future connections.

Please acknowledge receipt of this addendum along with its date on the bid form. Bids will not be accepted without acknowledge of this addendum.

Kelly W. Winkler, P.E.
Senior Civil Engineer – City of Hickory

Attachments: